

TÜV Rheinland Industrie Service GmbH
Postfach, 51101 Köln

GE Intelligent Platforms
2500 Austin Drive
Charlottesville, VA 22911
United States of America

Oliver Busa
Kst. 968

Tel. +49/221/806-2102
Fax +49/221/806-1539
Mail oliver.busa@
de.tuv.com
Web www.tuv.com

2010-04-23

To whom it may concern

This letter confirms that the formally known company GE Fanuc Automation North America, Inc. as listed on the certificates no.: 968/EZ 106.00/00 and no.: 968/EZ 106.01/01 has go-to-market with the new company name


GE Intelligent Platforms
2500 Austin Drive
Charlottesville, VA 22911
United States of America

The new company GE Intelligent Platforms is the valid manufacturer and licence holder of the systems listed on the certificates no.: 968/EZ 106.00/00 and no.: 968/EZ 106.01/01.


Best regards from Cologne

Automation, Software
and Information Technology
Business Unit System and Application FS

ppa.


Dipl.-Ing. Heinz Gall

i. A.


Dipl.-Ing. (FH) Oliver Busa

TÜV Rheinland
Industrie Service GmbH
Am Grauen Stein
51105 Köln

Tel +49 221 806-0
Fax +49 221 806-1753
Mail industrie-service@
de.tuv.com

Geschäftsführung:
Dr.-Ing. Frank Voßloh
(Specher)
Rose-Linde Delliehausen

Vorsitzender des
Aufsichtsrates
Friedrich Hecker

Köln HRB 26876

Web www.tuv.com

ZERTIFIKAT

Nr./No. 968/EZ 106.01/01

CERTIFICATE

Prüfgegenstand/Product tested		Hersteller/Manufacturer	
GMR Phase IV Genius Modular Redundancy (TMR, Duplex and Simplex), fail safe and/or fault tolerant safety system, for safety applications including (but not limited to) ESD and fire & gas applications		GE Fanuc Automation North America, Inc. USA-Charlottesville, Virginia 22906 United States of America in cooperation with Silvertech International Plc UK-Horsham, West Sussex RH12 4PN United Kingdom	
Typbezeichnung/Type designation		Verwendungszweck/Intended application	
Genius Modular Redundancy Flexible Triple Modular Redundant System, consisting of GE Fanuc 90-70 controllers with Genius I/O		Safety related applications, where A) the safe state is the de-energised state, e.g. Emergency Shutdown Systems (ESD) B) the safe/demand state is the energised state, e.g. fire & gas applications (F&G)	
Prüfgrundlagen Codes and standards forming the basis of testing	DIN V 19250/05.94 DIN V VDE 0801/01.90 + A1 10/94 IEC 61508 (1 - 7)/2000 IEC 61131-2/2000 DIN EN 50178/04.98 EN 55011/91 (CISPR 11) IEC 61000-4-2, 3, 4, 5	IEC 60068-2-1, 2, 6, 14, 27, 30 EN 54-2/12.97 NFPA 72/96 DIN VDE 0116/10.89 NFPA 8501/97 NFPA 8502/99	
Prüfungsergebnis Test results	Suitable for safety related applications according to requirement classes up to 6 (DIN V 19250/05.94) and up to SIL 3 (IEC 61508) considering the specific configurations as detailed and reprinted in the GMR user manual.		
Besondere Bedingungen Specific requirements	The TÜV Guidance is contained in the user's manuals GFK 1277C (GMR) and GFK 1649 (F&G) and must be considered. For safety related applications modules from the list of approved modules (GFT307d) must be used.		

Der Prüfbericht Nr. 968/EZ 106.01/01 vom 2001-09-24 ist Bestandteil dieses Zertifikates.

Dieses Zertifikat ist nur gültig für Erzeugnisse, die mit dem Prüfgegenstand übereinstimmen. Es wird ungültig bei jeglicher Änderung der Prüfgrundlagen für den angegebenen Verwendungszweck.

The test report No. 968/EZ 106.01/01 dated 2001-09-24 is an integral part of this certificate.

This certificate is valid only for products which are identical with the product tested. It becomes invalid at any change of the codes and standards forming the basis of testing for the intended application.