



TÜVRheinland®

ZERTIFIKAT CERTIFICATE

Nr./No. 968/EZ 128.19/09

Prüfgegenstand Product tested	Safety Related Programmable Electronic System HIMatrix	Zertifikats- inhaber Licence holder	HIMA Paul Hildebrandt GmbH + Co. KG Albert-Bassermann-Straße 28 68782 Brühl bei Mannheim Germany
Typbezeichnung Type designation	HIMatrix F20 HIMatrix F30 HIMatrix F31 HIMatrix F35 HIMatrix F60 HIMatrix RIO-NC	Hersteller Manufacturer	same as licence holder
Prüfgrundlagen Codes and standards forming the basis of testing	IEC 61508, Part 1 - 7:1998-2000 IEC 61511:2004 EN ISO 13849-1:2008 EN 62061:2005 EN 50156-1:2004 EN 12067-2:2004 EN 298:2003 EN 230:2005		EN 61131-2:2007 EN 61000-6-2:2005 EN 61000-6-4:2007 NFPA 85:2007 NFPA 86:2007 F60 and F35: EN 54-2:1997/A1:2007 NFPA 72:2007
Bestimmungsgemäße Verwendung Intended application	Safety Related Programmable Electronic System for process control, emergency shut down and machinery, where the safe state is the de-energized state. The product complies with the requirements of the relevant standards (Cat. 4 / PL e acc. to EN ISO 13849-1, SIL CL 3 acc. to EN 62061 / IEC 61508) and can be used in applications up to Cat. 4 / PL e acc. to EN ISO 13849-1 and SIL 3 acc. to EN 62061 / IEC 61508.		
Besondere Bedingungen Specific requirements	For the use of the systems the test report mentioned above, the Safety Manual, the User Guides and the official list of product documentation, hardware components and software modules released by HIMA and TÜV Rheinland have to be considered.		
This certificate is valid from 2009-11-23 until 2014-11-23.			



Der Prüfbericht-Nr.: 968/EZ 128.19/09 vom 23.11.2009 ist Bestandteil dieses Zertifikates.

Der Inhaber eines für den Prüfgegenstand gültigen Genehmigungs-Ausweises ist berechtigt, die mit dem Prüfgegenstand übereinstimmenden Erzeugnisse mit dem abgebildeten Prüfzeichen zu versehen.

The test report-no.: 968/EZ 128.19/09 dated 2009-11-23 is an integral part of this certificate.

The holder of a valid licence certificate for the product tested is authorized to affix the test mark shown opposite to products, which are identical with the product tested.

TÜV Rheinland Industrie Service GmbH
Geschäftsfeld ASI
Automation, Software und Informationstechnologie
Am Grauen Stein, 51105 Köln
Postfach 91 09 51, 51101 Köln

2009-11-23

Datum/Date

Firmenstempel/Company stamp

Dipl.-Ing. Heinz Gall