



TÜVRheinland®

ZERTIFIKAT
CERTIFICATE

Nr./No.: 968/EZ 188.03/10

Product tested	Safety related I/O system FLEX-I/O	Licence holder	Rockwell Automation Asia Pacific Business Center Pte. Ltd. No. 2 Corporation Road #06-05/10 Corporation Place 618494 Singapore
Typbezeichnung Type designation	FLEX-I/O system The actual revision and official list of the product documentation, hardware components and software modules have to be considered. Please refer to the home-page of TÜV: http://www.tuvasi.com/	Manufacturer	same as licence holder
Codes and standards forming the basis of testing	IEC 61508, Part 1 - 7:2000 IEC 61131:2007 EN 50156-1:2004 (partly applied) EN 54-2:1997 / A1: 2006 (partly applied) EN 50178:1997 EN 61000-6-2:2005 EN 61000-6-4:2007		
Bestimmungsgemäße Verwendung Intended application	Safety Related I/O-System for process control, emergency shut down and where the safe state is typical the de-energized state. The devices comply with the requirements of the relevant standards and can be used in applications up to SIL 2 acc. to IEC 61508.		
Specific requirements	For the use of the systems the test report mentioned above, the Safety Reference Manual, the User Manuals and the actual revision of the official list of product documentation, hardware modules and software components released by Rockwell Automation and approved by TÜV Rheinland have to be considered.		
This certificate is valid until 2015-02-11.			

The test report-no.: 968/EZ 188.03/10 dated 2010-02-11 is an integral part of this certificate.

This certificate is valid only for products which are identical with the product tested. It becomes invalid at any change of the codes and standards forming the basis of testing for the intended application.

TÜV Rheinland Industrie Service GmbH
Geschäftsfeld ASI
Automation, Software und Informationstechnologie
Am Grauen Stein, 51105 Köln
Postfach 91 09 51, 51101 Köln

Cologne, 2010-02-11

Zertifizierungsstelle bei der TÜV Rheinland
Industrie Service GmbH

Dipl.-Ing. Heinz Gall