



TÜVRheinland®

ZERTIFIKAT CERTIFICATE

Nr./No.: 968/EZ 191.09/10

Product tested	Safety Related Programmable Logic Controller GuardLogix Including Safe Function Blocks	Licence holder	Rockwell Automation Safety Logix Systems 1201 South Second Street Milwaukee, WI 53204 United States of America
Type designation	GuardLogix modules as listed in the Safety Reference Manual, Publication Number 1756-RM093F	Manufacturer	same as licence holder
Codes and standards forming the basis of testing	IEC 61508, Part 1 - 7:2000 ISO13849-1:2006 / Technical Corr. 1: 2009 EN 62061:2005 IEC 61511-1:2003 / Corrigendum 1: 2004 EN 954-1:1996 IEC 61131-2:2007 EN 50156-1:2004 NFPA 79:2007 AS4024.1:2006		ANSI B11.19-2003 ANSI RIA 15.06-1999 NFPA 85:2007 NFPA 86:2007 AS4024.1:2006 EN 50178:1997 EN 60204-1:2006/A1:2009 EN 61000-4-5:2006 EN 61000-6-2:2005 EN 61000-6-4:2007
Bestimmungsgemäße Verwendung Intended application	The devices comply with the requirements of the relevant standards (Cat. 4 / PL e acc. to EN ISO 13849-1, SIL CL 3 acc. to EN 62061 / IEC 61508) and can be used in applications up to Cat. 4 / PL e acc. to EN ISO 13849-1 and SIL 3 acc. to EN 62061 / IEC 61508.		
Specific requirements	For the use of the systems the test report mentioned above, the Safety Reference Manual, the User Manuals and the actual revision of the official list of product documentation, hardware modules and software components released by Rockwell Automation and approved by TÜV Rheinland have to be considered.		
This certificate is valid until 2015-03-30.			



Der Prüfbericht-Nr.: 968/EZ 191.09/10 vom 30.03.2010 ist Bestandteil dieses Zertifikates.

Der Inhaber eines für den Prüfgegenstand gültigen Genehmigungs-Ausweises ist berechtigt, die mit dem Prüfgegenstand übereinstimmenden Erzeugnisse mit dem abgebildeten Prüfzeichen zu versehen.

The test report-no.: 968/EZ191.09/10 dated 2010-03-30 is an integral part of this certificate.

The holder of a valid licence certificate for the product tested is authorized to affix the test mark shown opposite to products, which are identical with the product tested.

TÜV Rheinland Industrie Service GmbH
Geschäftsfeld ASI
Automation, Software und Informationstechnologie
Am Grauen Stein, 51105 Köln
Postfach 91 09 51, 51101 Köln

2010-03-30

Zertifizierungsstelle bei der TÜV Rheinland Industrie Service GmbH

Dipl.-Ing. Heinz Gall