

TÜV Rheinland Industrie Service GmbH
Postfach, 51101 Köln

Honeywell Safety Management Systems
Mr. Wim van Oort
Rietveldenweg 32
5222 AC 's-Hertogenbosch
The Netherlands

Andreas Hesse
Kst. 968

Tel. +49/221/806-4358
Fax +49/221/806-1539
Mail andreas.hesse@
de.tuv.com
Web www.tuv.com

2009-07-13

Safety Manager EMC-Compatibility

To whom it may concern,

The Safety PLC Safety Manager R130.1 has been tested to the EMC levels according to IEC 61326-3-1.

The tests have been carried out by an accredited laboratory and have been passed.

The results are accepted by the test institute.


Between the actual version R131.5 and the R130.1 no significant hardware changes were carried out, so that the result are considered valid for R131.5, too.

If you have any questions do not hesitate to contact us.

Best regards from Cologne

Automation, Software
and Information Technology
Business Unit System and Application FS

ppa.


Dipl.-Ing. Heinz Gall

i. A.


Dipl.-Ing. Andreas Hesse

TÜV Rheinland
Industrie Service GmbH
Am Grauen Stein
51105 Köln

Tel. +49 221 806-0
Fax +49 221 806-1753
Mail industrie-service@
de.tuv.com

Geschäftsführung
Ralf Berker
Rose-Linde Delliehausen
Friedrich Hecker
Peter Tolls

Vorsitzender des
Aufsichtsrates
Prof. Dr. -Ing. habil.
Bruno O. Braun

Köln HRB 26876

Web www.tuv.com