

TRICON Version 10.0.3 Approved Components List
 Last edit: 27 October, 2007, most current version: <http://www.tuv-fs.com>

The following components have been approved by TUV Rheinland for use in TRICON Version 10 systems.

Module Name		Model	Firmware Revision
ACM	Advanced Communications Module	4609, 4609N	4930 + 5584
AI	0-10V DC (NIAI)	3701, 3701N	5661
AI	0-5/0-10V DC (EIAI)	3703E, 3703EN	5916
AI	0-5V DC (NIAI)	3700, 3700A, 3700AN	5661
AI	(DC coupled thermocouple) (NIAI)	3706A, 3706AN	5661
AI	0-5/0-10V DC coupled, commoned (HDI)	3704E, 3704EN	5910
AI	Isolated Thermocouple (EIAI)	3708E, 3708EN	5916
AO	4-20 (EAO)	3805E, 3805EN	5897
DI	115V AC/DC HiKV (EDI)	3501T, 3501TN	5909
DI	24/48V DC (HDI)	3504E, 3504EN	5910
DI	24V AC/DC (EDI)	3503E, 3505EN	5909
DI	24V DC Single (SDI)	3564	5504
DI	24V DC (EDI)	3505E, 3503EN	5909
DI	48V AC/DC (EDI)	3502E, 3502EN	5909
DO	115V AC non commoned (EDO)	3601T, 3601TN	5781
DO	120V DC supervised (HiKV) (TSDO2)	3623T, 3623TN	5940
DO	120V DC (HVDO)	3603T, 3603TN	6142
DO	24V DC (Dual) (DDO)	3664	5492
DO	24V DC (FS) (DDO FS)	3674	5493
DO	24V DC non commoned (EDO)	3604E, 3604EN	5781
DO	24V DC supervised (TSDO2)	3624, 3624N	5940
DO	48V DC non commoned (EDO)	3607E, 3607EN	5781
DO	24V DC supervised (ESDO)	3614E, 3615E	5784
DO	48V DC supervised (ESDO)	3617E	5784
EICM	Enhanced Intelligent Communications Module	4119, 4119A, 4119AN	4930 + 5276
MP	EMP III	3008	Build 77: 6056 (TSX) 6054 (IOCCOM)
NCM	Network Interface Module	4329, 4329N	4930 + 5721
NCMG	Network Interface Module	4329G	4930 + 5721
PI	Pulse Input Module (EPI)	3510/3511, 3510N/3511N	5647
PT	24V DC (PT)	3515	5503
RO	Dry Contact HighKV (ERO)	3636T, 3636TN	5777
RXM	Primary single mode fiber (SRXMP)	4210, 4210N	3310
RXM	Primary (RXMP)	4200	3310
RXM	Remote single mode fiber (SRXMS)	4211, 4211N	3310
RXM	Remote (RXMS)	4201	3310
SMM	Safety Manager Module	4409	5660 + 4508
TCM	Tricon Communications Module	4351, 4352	Build 77 (6107)
Power Supplies		-	-
Chassis (High Density and Low Density)		-	-
Termination products		-	-
TS1131 Workbench, CEM Editor, Workbench Demo (TS1131 V3.X and V4.0: Windows NT 4, SP5 or later; Windows 2000, SP2 or later TS1131 V4.1: Windows 2000, SP2 or later, Windows XP Professional)		-	V4.1

