



CERTIFICATE

No. Z10 09 04 20160 010

Holder of Certificate: Honeywell Safety Management Systems

Rietveldenweg 32
5222 AR Hertogenbosch
THE NETHERLANDS

Factory(ies): 20160

Certification Mark:



Product: Safety Related Programmable Electronic System

Model(s): FSC Fail-Safe Controller System Family
DMR, QMR, 1001D, 1002D

Parameters: Nominal supply voltage: 24 VDC

Tested according to: IEC 61508:2000 (Part 1-4), SIL 1-3
IEC 61511-1:2003, SIL 1-3
IEC 61511-2:2004, SIL 1-3
IEC 61511-3:2004, SIL 1-3

The listed product was tested on a voluntary basis and complies with the relating standards or directives. The certification mark shown above can be affixed on the product. The certification mark must not be altered in any way. See also notes overleaf.

Test report no.: SH99495C

Date, 2009-04-09

Page 1 of 1

